

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:08 pm

PWS ID: UTAH13042 **Name:** ELKRIDGE WATER COMPANY

Legal Contact: ELKRIDGE ESTATES **Rating:** Approved
WADE RAYMOND HEATON **Rating Date:** 11/17/2004

Address: PO BOX 100013 **Activity Status:** Active
ALTON, UT 84710

Phone Number: 435-648-2029

City Served (Area):

County: KANE COUNTY

System Type: Non-community **Last Inv Update:** 09/01/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/31/2009 **Total Dsgn Cap:**
Population: 40 **Surveyor:** JOHN L CHARTIER **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	HEATON, WADE RAYMOND		435-891-1997	435-648-2029	wheaton@scinternet.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	64
			64 Total Svc Connections

Storage

Total Storage: 329,400 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST003	TANK 1, UNITS 1 AND 2	Ground	19,400			A	NO
ST001	TANK 2, UNIT 3	Ground	170,000 GAL	Steel		A	
ST002	TANK 3, UNIT 4	Ground	140,000 GAL	Steel		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	UNIT 4 BOOSTER PUMP	A		P			

Distribution System

Pump Type	Total Dyn Head		Pressure Adequate	Cross Connection	Auhority Statement
	ft H2O	P.S.I.			
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL # 1	Active	WL		30 GPM	33 GPM	Yes	GW	Seasonal		
WS002	WELL # 2	Inactive	WL		65 GPM	65 GPM	Yes	GW	Seasonal		
WS003	WELL #3	Active	WL		100 GPM	100 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.